

# ARCHITECTURAL SPECIFICATIONS PANASONIC ADVANCED VENTILATION SERIES

## SUPER LOW PROFILE FAN/LIGHT COMBINATION CEILING MOUNTED VENTILATING FANS

### **FV-05VFL1 WhisperFit-Lite**

Ventilating fan and light shall be of the ceiling mount, Energy Star rated type, with no less than 50 CFM and no more than 0.4 sone as certified by the Home Ventilating Institute (HVI) at 0.1 static pressure in inches water gauge. Fan power consumption shall be no greater than 14 watts and Energy Star rated with efficiency rating of no less than 3.5 cfm/watt. The motor shall be totally enclosed, four pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Fan shall be UL and cUL listed for tub/shower enclosure when used with GFCI branch circuit wiring.

### **FV-07VFL1 WhisperFit-Lite**

Ventilating fan and light shall be of the ceiling mount, Energy Star rated type, with no less than 70 CFM and no more than 0.9 sone as certified by the Home Ventilating Institute (HVI) at 0.1 static pressure in inches water gauge. Fan power consumption shall be no greater than 19 watts and Energy Star rated with efficiency rating of no less than 3.6 cfm/watt. The motor shall be totally enclosed, four pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Fan shall be UL and cUL listed for tub/shower enclosure when used with GFCI branch circuit wiring.

### **FV-09VFL1 WhisperFit-Lite**

Ventilating fan and light shall be of the ceiling mount, Energy Star rated type, with no less than 90 CFM and no more than 1.5 sone as certified by the Home Ventilating Institute (HVI) at 0.1 static pressure in inches water gauge. Fan power consumption shall be no greater than 24 watts and Energy Star rated with efficiency rating of no less than 3.8 cfm/watt. The motor shall be totally enclosed, four pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Fan shall be UL and cUL listed for tub/shower enclosure when used with GFCI branch circuit wiring.